

ADDENDUM NO. 1

**ITB 5530-2018, Certified Alarm System Contractor for Cobb Middle School
Fire Alarm Replacement Project**

SCHOOL BOARD OF LEON COUNTY, FLORIDA

ITEM #1

Section C, Bid Form is hereby deleted in its entirety and replaced with Section C, Revised Bid Form. All references in the solicitation to Section C, Bid Form are hereby revised to refer to Section C, Revised Bid Form.

ITEM #2

The following Electrical Plan Revisions number 1 through 16 are attached hereto and made a part of the plans.

ADDENDA ACKNOWLEDGMENT: The undersigned also acknowledges the receipt of the following Addenda:

Addendum No. 1 Dated: April 3, 2018

Vendor Name: _____
Vendor Address: _____
Name Title: _____
Signature: _____

SECTION C

REVISED BID FORM

SUBMIT IN DUPLICATE ON CONTRACTOR'S LETTERHEAD

SCHOOL BOARD OF LEON COUNTY, FLORIDA
PURCHASING DEPARTMENT
3397 WEST THARPE STREET
TALLAHASSEE, FLORIDA 32303

DATE: Tuesday, April 10, 2018
TIME: 2:00 pm local time
OWNER'S BID NO. 5530-2018

REFERENCE: Cobb Middle School– Fire Alarm Replacement

I (We), the undersigned, hereby declare that the only persons, firm or corporation interested in this Proposal or the Contract to be entered into, as principals, are named herein, and that this Proposal is made without collusion with any person, firm or corporation, and that it is in all respects fair and in good faith.

The undersigned, hereinafter called "Bidder", having visited the site of the proposed project and become familiar with the local conditions, nature and extent of the work, and having examined carefully the drawings, specifications, the Form of Agreement, and other Contract Documents, with the bond requirements therein, proposes to furnish all labor, materials, equipment and other items, facilities, and services for the proposed execution and completion of the [insert project and school name] in full accordance with the drawings and specifications prepared by [insert name and address of firm], in full accordance with the Advertisement for Bids, Instruction to Bidders, Agreement and all other Contract Documents; and if awarded the Contract, I (We) will contract with the SCHOOL BOARD OF LEON COUNTY, FLORIDA to furnish all necessary labor, equipment, materials, and incidental costs, and that I (We) will substantially complete all necessary work in accordance with the Specifications and Drawings, and the requirements under them on or before August 1, 2018 for the following Bid price:

Base Bid \$ _____

UNIT PRICING: In order to have predetermined pricing that may be used for the addition or deletion of devices on this project, Bidders shall include in their Bid Package a list of unit prices for the following (installed, programmed, and functioning as part of the system):

Heat Detector	\$ _____
Smoke Detector	\$ _____
Duct Smoke Detector	\$ _____
Combination Co & Heat Detector	\$ _____
Combination Co & Smoke Detector	\$ _____
Pull Station	\$ _____
Strobe Only Visual Device	\$ _____
Speaker/Strobe Audio/Visual Device	\$ _____

Sti Protector Tamper Proof Cover	\$
50 Feet Of Conduit & Cable For Extending Any Above Device	\$

The undersigned further agree(s) to bear the full cost of maintaining all work until the final acceptance, as provided in the Contract Documents.

The above amount, if accepted by the Owner shall form a Contract to be entered into. The undersigned agree(s) to furnish a sufficient and satisfactory bond in the sum of not less than 100 percent (100%) of the Contract Price of the work awarded.

It is further agreed that in the case of failure on the part of the undersigned to execute said Contract and Bond under the conditions of this Proposal within eight (8) "Owner Business Days" after the award of the Contract, the accompanying Proposal Guaranty, made payable to the SCHOOL BOARD OF LEON COUNTY, FLORIDA of not less than five percent (5%) of the total actual bid (Base Bid plus all Alternates), shall be forfeited as liquidated damages; otherwise, said Guaranty is to be returned to the undersigned upon the delivery of the executed Contract, a satisfactory bond and other specified documents.

Name of Bonding Company:	
Local Agent's Address:	
Phone No.	

Attached hereto, is the said Proposal Guaranty in the form of a Bid Bond, Certified Check, Cashier's Check in the amount of _____ Dollars (\$_____), according to the provisions contained herein and to the conditions and provisions of the Contract Documents.

Included in this bid are the following:

Forms/Exhibits

1. A – Prohibition Against Contingency Fees
2. B – LCSB Sworn Statement – Contract/Public Entity Crime Law: Assurance of conformance with Public Entity Crime Law, Section 287.133(2)(a), Florida Statute
3. C – Conflict of Interest Disclosure
4. D – Debarment Information/Form
5. E – Affidavit for Claiming Local Purchasing Preference (LCS Policy 6450)

I (We) hereby acknowledge receipt of the following Addendum, if any, issued during the bidding period: (List Addendum No. and Date)

Addendum No.	Date
Addendum No. 1	April 3, 2018

It is understood by the Bidder that the Owner shall post its intent to award or reject this Bid. The intent shall remain posted for a period of three (3) working days. Failure to file a protest within the time prescribed in Section 120.57(3), Florida Statutes, shall constitute a waiver of proceedings under Chapter 120, Florida Statutes.

I (We), the undersigned, hereby certify that I (We) have carefully examined the foregoing Proposal after the same was completed and have verified each item placed thereon; and I (We) agree to indemnify, defend and save harmless, the SCHOOL BOARD OF LEON COUNTY, FLORIDA and their agents, against any cost, damage or expense which it may incur or be caused by an error in my (our) preparation of same.

The following license is current and the Bidder agrees to maintain it in effect throughout the project duration:

Florida Construction Industries Licensing Board Certification (State Certified of County Registered).

Name of Holder

License Number

In witness whereof, the Bidder has here unto set his/her signature and affixed his/her seal this ____ day of _____, A.D. 20____.

(Seal)

By: _____
(Signature)

(Print Name)

Title: _____

END OF SECTION C

THIS PAGE INTENTIONALLY LEFT BLANK

Electrical Plan Revisions
April 3, 2018

ELECTRICAL

1. **SHEET E1.0, FIRE ALARM PROJECT NOTES:** Delete Note #17.
2. **SHEET E3.2, FACP ROOM:** Work Note adjacent to smoke detector in this room shall be changed to 7; "Provide new device in location indicated".
3. **SHEET E3.8, WORK NOTE #7:** Work Note #7 on this sheet shall be modified to read: "Existing tamper and flow switches shall remain. Contractor shall test and verify proper operation. Provide addressable modules for monitoring by the Fire Alarm System".
4. **SHEET E3.9, GYMNASIUM:** Provide a shutdown relay on the Gymnasium PA/Sound System. When the Fire Alarm System is in general alarm, it will shutdown the PA/Sound System.
5. **SHEET E3.11, MECHANICAL ROOM 03-147A:** Disregard Work Note #4 on existing CO detector. This is a mechanical system detector and is not connected to the Fire Alarm System.
6. **SHEET E3.11, TOILETS 03.045a AND 03-045F:** Provide a new addressable strobes only visual device in each of these toilet areas.
7. **SHEET E3.12, MECHANICAL ROOM 03-053:** Disregard Work Note #11 on the existing CO detector. This is a mechanical system detector and is not connected to the Fire Alarm System.
8. **SHEET E3.12, OFFICE 03-049C:** Work Note adjacent to strobe device in this room shall be changed to 1: "Replace existing non-addressable fire alarm device with a new addressable device of the same application".
9. **SHEET E3.12, PRACTICE ROOM 03-049B:** Work Note adjacent to strobe device in this room shall be changed to 1: "Replace existing non-addressable fire alarm device with a new addressable device of the same application".
10. **SHEET E3.12, PRACTICE ROOM 03-049A:** Provide a new strobe only visual device on the west wall adjacent to the door.
11. **SHEET E3.12, OFFICE 03-049F:** Provide a new strobe only visual device on the north wall above the pull station.
12. **SHEET E3.12, MUSIC STORAGE ROOM 03-049E:** Provide a new strobe only visual device on the south wall adjacent to the door.
13. **SHEET E3.12, MUSIC STORAGE ROOM 03-049D:** Work Note adjacent to the horn/strobe device in this room shall be changed to: "12, replace existing horn/strobe device with a new addressable strobe only device".
14. **SHEET E3.12, WOOD SHOP 03-037:** Existing pull station at roll up door shall be removed. Add a new pull station on the wall adjacent to the double doors at the east end of this room.
15. **SHEET E4.0, WORK NOTE #11:** Remove the second sentence of this Work Note. A general alarm shall NOT shutdown all air handlers.

16. **SHEET E4.0, WORK NOTE #13**: Work Note #13 shall be modified to read: "Existing flow switches at fire sprinkler backflow preventer shall remain. Provide addressable modules for monitoring by the fire alarm system".

REMAINDER OF PAGE INTENTIONALLY LEFT BLANK