

## ADDENDUM #001 RFP 492-2022 Data Cabling Equipment and Services (E-Rate)

Date: November 15, 2021

Solicitation: RFP 492-2022 Data Cabling Equipment and Services (E-Rate)

Proposals Due: December 14, 2021, at 2:00 P.M. EST

Failure to file a protest within the time prescribed in Section 120.57(3), Florida Statutes, or failure to post the bond or other security required by law within the time allowed for filing a bond shall constitute a waiver of proceedings under Chapter 120, Florida Statutes.

Please be advised that the changes below are applicable to the original specifications of the above-referenced solicitation. Added or new language to the RFP is highlighted in yellow, while deleted language has been stricken.

This Addendum includes the following revisions:

## Change No. 1:

Revision to RFP Timeline:

Anticipated Date the District will Advertise its Notice of Board Decision	January 31, <del>2021</del> <mark>2022</mark>	District Website <a href="https://www.leonschools.net/Page/4411">https://www.leonschools.net/Page/4411</a>
---	---	--

This Addendum also includes the Board's written answers to the timely written questions received. All referenced attachments are posted at: <a href="https://www.leonschools.net/Page/4411">https://www.leonschools.net/Page/4411</a>

[The Remainder of This Page Was Left Blank Intentionally]

## Responses to Written Questions RFP 492-2022

## **Data Cabling Equipment and Services (E-Rate)**

	Question	Answer
1.	Is there a preferred color for the Cat5e/6/6a cable drops?	Acceptable colors are blue, yellow, green, red, black, and grey.
2.	Is there an idea of how much feet of cabling that will be needed per drop?	Each drop will require approximately 100 feet of cable, depending on the individual project scope.
3.	How many cable drops will there be?	The number of drops will vary depending on the individual project scope.
4.	Will the patch panels need to be punch down or feedthrough?	The patch panels must be punch down.
5.	Is the 7' Floor Mounted Equipment Rack and 4 Post Floor Mounted Equipment Rack meant to be open framed?	The racks should be open and enclosed within a cabinet.

[The Remainder of This Page Was Left Blank Intentionally]