



ADDENDUM No. 1 TO ORIGINAL INVITATION TO BID

DATE: May 28, 2014

BID No.: 5266-2014 Woodville Middle School Fire Sprinkler Project – Portable Classrooms

OPENING DATE OF BID: June 3, 2014 @ 2:00 P.M. EST (Addendum does not change the opening date of the bid)

This addendum is being issued to make the following changes, corrections, clarifications and additions to the bidding document. The information in this addendum modifies and changes the original bidding document and takes precedence over the original document. Receipt of this addendum shall be acknowledged by the bidder signing and dating below and submitting this document with your bid proposal form. Failure to acknowledge this addendum may preclude consideration of the bid proposal for award.

Additions and Changes to Scope of Work:

Section IV. (A) page 12

1. Install PIV on east side of storage shed.
2. Each portable shall have a riser with the following appearances
 - A. Externally resettable dry pipe valve
 - B. Pressure switch
 - C. Butterfly control valve
3. Each portable shall have an inspectors\trip test valve at most remote point
4. An air compressor shall be provided inside of storage shed piping to follow underground sprinkler piping to each portable
5. Drain water shall be captured on site i.e. on ground

Fire alarm conduit shall be put in ground with sprinkler piping

No FDC shall be required at this time portables comply with NFPA 13 2007 8.17.2.2 (3)
No fire hydrant is required at this time. Fire hydrant will be added during future expansion.

Work provided by others

1. All signage required by AHJ
2. Fire alarm equipment required

TO QUALIFY YOUR BID, OF WHICH THIS ADDENDUM BECOMES A PART, RECEIPT OF IT MUST BE ACKNOWLEDGED AND RETURNED WITH YOUR BID.

VENDOR NAME VENDOR ADDRESS

NAME TITLE

SIGNATURE