



ADDENDUM No. 2 TO ORIGINAL INVITATION TO BID

DATE: May 29, 2014

BID No.: 5266-2014 Woodville Middle School Fire Sprinkler Project – Portable Classrooms

OPENING DATE OF BID: June 3, 2014 @ 2:00 P.M. EST (Addendum does not change the opening date of the bid)

This addendum is being issued to make the following changes, corrections, clarifications and additions to the bidding document. The information in this addendum modifies and changes the original bidding document and takes precedence over the original document. Receipt of this addendum shall be acknowledged by the bidder signing and dating below and submitting this document with your bid proposal form. Failure to acknowledge this addendum may preclude consideration of the bid proposal for award.

Approved Alternate:

C900 piping has been approved as an alternate for underground piping to portables.

TO QUALIFY YOUR BID, OF WHICH THIS ADDENDUM BECOMES A PART, RECEIPT OF IT MUST BE ACKNOWLEDGED AND RETURNED WITH YOUR BID.

VENDOR NAME VENDOR ADDRESS

NAME TITLE

SIGNATURE