



ADDENDUM No. 1 TO ORIGINAL INVITATION TO BID

Date: September 24, 2019

Re: Bid No. 5587-2020 Deerlake Middle School Building 8 Storm Water System Adjustments

Bid Opening: October 2, 2019 @ 2:00 P.M. EST (Addendum does not change the opening date of the bid)

This addendum is being issued to make the following changes, corrections, clarifications and additions to the bidding document. The information in this addendum modifies and changes the original bidding document and takes precedence over the original document. Receipt of this addendum shall be acknowledged by the bidder signing and dating below and submitting this document with your bid proposal form. Failure to acknowledge this addendum may preclude consideration of the bid proposal for award.

Clarifications of Questions from Pre-Bid Meeting:

1. Plan shows LCS will handle the waterproofing. **Waterproofing of the wall will not be performed.**
2. Plan shows a note to 'Grade to new basin'. **Grading should begin 10 feet Southeast of building 8. Grade along building 8 to placed drain in all directions.**
3. There is an existing downspout, not shown on the plan, that should be included in this scope of work - tie into the new stormdrain system. **No work needed at this time.**
4. Item 7 - Description of Work, Note b says to secure and control the area. **Orange barricade fencing is acceptable. Fencing to be maintained and upright at all times.**
5. Item 7 - Description of Work, Note e says to identify any trees to be removed. **Contractor has authorization to remove any trees as needed.**
6. Item 7 - Description of Work, Note n (also note LS200.2.0) says to sod entire affected area or all disturbed areas. **All areas effected by project shall be restored and sod placed. Access road will not require sod, contractor at completion of project shall level and remove ruts from access road.**
7. Item 7 - Description of Work, Note LS200.3 says all landscape areas as defined herein shall be covered 100% by a temporary irrigation system. **Contractor will need to keep grass watered until close out of project upon completion the Principal has committed to keep grass watered.**
8. There are three (3) classrooms close to where most of the work will occur. **Principal has committed to moving the 3 effected classrooms when needed. Contractor to plan and schedule with Principal as needed.**

**TO QUALIFY YOUR BID, OF WHICH THIS ADDENDUM BECOMES A PART,
RECEIPT OF ADDENDUM MUST BE ACKNOWLEDGED AND RETURNED WITH YOUR BID.**

VENDOR NAME

VENDOR ADDRESS

NAME

TITLE

SIGNATURE