



SUPERINTENDENT ROCKY HANNA

**BOARD CHAIR**

Rosanne Wood

**BOARD VICE CHAIR**

Laurie Lawson Cox

**BOARD MEMBERS**

Marcus Nicolas

Darryl Jones

Alva Swafford Smith

**To:** Mr. Desmond Cole, Principal, Amos P. Godby High School  
Ms. Jennifer Powell, Assistant Principal, Amos P. Godby High School  
Mr. Terry Gallon, Assistant Principal, Amos P. Godby High School  
Mr. Alex Stemie, Assistant Principal, Amos P. Godby High School  
Mr. Ryan Peck, Director of Maintenance  
Mr. Daniel "Danny" Allbritton, Director of Construction

**From:** Mr. Tonnie W. Rollins, Project Manager, Fire & Safety Inspector

**Through:** Mr. LaRoderick E. McQueen, Certified Building Official/Director

**Date:** January 7, 2025

**Subject:** SREF Inspection for Amos P. Godby High School

Attached to this memorandum is the State Requirements for Educational Facilities (SREF) Inspection Report for the above referenced facility. The report identifies the deficiencies and corrective actions for the entire site. The column labeled **MOC** identifies the entity responsible for correcting each deficiency, as follows:

- Line items with an **M (Maintenance)** in the **MOC** column are to be addressed by the Maintenance Department. Work orders will be generated addressing each deficient item. Upon completion of all work orders, please have Code Enforcement staff sign off to confirm completion.
- Line items with an **O (Operational)** in the **MOC** column are to be addressed by site based staff or through work order submission to the Maintenance Department. These items need to be corrected within the proposed time allotment, prior to the follow-up inspection.
- Line items with a **C (Construction)** in the **MOC** column are to be addressed by the Construction/Facilities Department through Capital Outlay projects or a corrective action plan developed.

Notification of the completion or corrective action plan of the fore-mentioned deficient items need to be submitted to the Code Enforcement Department. Please initial and date the line items under your area of responsibility on the provided report to confirm completion. You may email Ms. LySandra Black at [blackl@leonschools.net](mailto:blackl@leonschools.net) or fax the report to (850) 617-1800, to her attention.


Please note a copy of this SREF inspection report will be forwarded to the Board and your Divisional Director.


*\*\*Additionally a separate inspection report has been provided for each portable at your site. In accordance with SREF Chapter 4 Section 4.4 (2)\*\**


If you have any questions or comments regarding any items noted on this report, please feel free to contact Mr. Tonnie W. Rollins at the Code Enforcement Department at (850) 617-1800 or email at [rollinst2@leonschools.net](mailto:rollinst2@leonschools.net). Thank you for your time and cooperation in this matter.

**ATTACHMENT**


**Cc:** Dr. Alan Cox, LCS Assistant Supervisor of School Management (with attachments)


10/29/2024				 <p><b>LEON COUNTY SCHOOLS</b></p> <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303</p> <p><b>COMPREHENSIVE SAFETY INSPECTION</b> FISCAL YEAR: 2024-2025</p>		<b>Amos P. Godby High School</b>					
INSPECTION DATE						SCHOOL/ FACILITY/CAMPUS					
INSPECTOR: Tonnie Rollins						1717 West Tharpe Street					
						Tallahassee, Florida 32303					
INSPECTOR SIGNATURE SIGNATURE DATE						F.I.S.H. NUMBER					
TYPE OF INSPECTION						037-0161-016					
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION											
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re-Inspection Correction Date	Site-Wide Building-Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT		
1	0001	010	O	Remove non-approved furniture that does not have NFPA label or certificate. NFPA 101-10.3.2							
2	0001	010	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)							
3	0001	012	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j							
4	0001	014	O	Storage in electrical and mechanical room is prohibited. SREF 5(17)(b)(2) c and (2)(8)(E)(i)					Paint Department		
5	0001	015	O	Door Blocked.					Locksmith		
6	0001	017	O	Walkway Obstructed.							
7	0001	018	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j					Building Automation		
8	0001	021	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j, Walkway obstructed.							
9	0001	024	O	Drinking water fountain needs to be secured.					Plumbing Department		
10	0002	001	O	Replace Audio System							
11	0002	002	M	Speaker on wall wired exposed							
12	0002	003B	O	Appliances must be plugged in to a dedicated outlet.							
13	0002	005	M	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j							
14	0002	006	M	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j					Plumbing Department		
15	0002	007	M	Replace sinks.							
16	0002	007	M	Broken or missing receptacle cover plate. SREF 5(2)(e)(8)(j), NFPA 70 406.8							
17	0002	007	M	Repair Thermostat.							


10/29/2024				 <p>LEON COUNTY SCHOOLS</p> <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303</p> <p>COMPREHENSIVE SAFETY INSPECTION FISCAL YEAR: 2024-2025</p>	<b>Amos P. Godby High School</b> <b>SCHOOL/ FACILITY/CAMPUS</b> 1717 West Tharpe Street Tallahassee, Florida 32303 <b>F.I.S.H. NUMBER</b> <b>037-0161-016</b>				
INSPECTION DATE									
INSPECTOR: Tonnie Rollins									
INSPECTOR SIGNATURE      SIGNATURE DATE									
TYPE OF INSPECTION									
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION									
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re-Inspection Correction Date	Site-Wide Building-Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT
18	0002	008	O	Replace damaged ceiling tile(s). SREF 5 (2) (e) (8) j					
19	0002	009	O	Storage in mechanical room is prohibited. SREF 5 (16)(6)a					
20	0002	010	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j					
21	0002	012	M	Replace and date stained and/or broken ceiling tiles	0				
22	0002	013	M	Water Fountain in hallway needs to be replaced or removed.	0				
23	0003	001A	O	Remove combustible materials from ceiling. NFPA 101-10.3.1	0				
24	0003	001A	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)	0				Roofing Department
25	0003	001A	O	Remove festive lights on walls.	0				
26	0003	001B	O	Remove combustible materials from ceiling. NFPA 101-10.3.1	0				
27	0003	001D	O	Remove festive lights off walls.	0				
28	0003	001E	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.	3				Structural Department
29	0003	001E	O	Remove combustible materials from ceiling. NFPA 101-10.3.1	0				
30	0003	001E	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)	1			Building Wide	SREF 5 8(c)(4)
31	0003	001F	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)	1				Roofing Department


10/29/2024				 <p>LEON COUNTY SCHOOLS</p> <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303</p> <p>COMPREHENSIVE SAFETY INSPECTION FISCAL YEAR: 2024-2025</p>		<b>Amos P. Godby High School</b>				
INSPECTION DATE						SCHOOL/ FACILITY/CAMPUS				
INSPECTOR: Tonnie Rollins						1717 West Tharpe Street				
						Tallahassee, Florida 32303				
INSPECTOR SIGNATURE				SIGNATURE DATE				F.I.S.H. NUMBER		
TYPE OF INSPECTION								037-0161-016		
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION										
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re-Inspection Correction Date	Site-Wide Building-Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT	
32	0003	001F	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j	1				Electrical Department	
33	0003	001G	O	Remove combustible materials from ceiling. NFPA 101-10.3.1	1					
34	0003	001H	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)						
35	0003	001H	O	Remove festive lights off walls.						
36	0003	001H	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1						
37	0003	001J	O	Wire on wall exposed. Light on wall						
38	0003	001L	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1						
39	0003	001L	O	Remove non-approved furniture that does not have NFPA label or certificate. NFPA 101-10.3.2						
40	0003	003	O	Pipes from sink need to be covered						
41	0003	004	O	Remove combustible materials from ceiling. NFPA 101-10.3.1						
42	0003	300	O	Replace water stained ceiling tiles. SREF 5 (2) (e) (8) j						
43	0003	300	O	Pipes from water fountain need to be covered.						
44	0003	300	O	Remove bookshelves in hallway.						
45	0004	001A	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1						




10/29/2024				 <p><b>LEON COUNTY SCHOOLS</b></p> <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303</p> <p><b>COMPREHENSIVE SAFETY INSPECTION</b> FISCAL YEAR: 2024-2025</p>		<b>Amos P. Godby High School</b> <b>SCHOOL/ FACILITY/CAMPUS</b> 1717 West Tharpe Street Tallahassee, Florida 32303					
INSPECTION DATE											
INSPECTOR: Tonnle Rollins											
INSPECTOR SIGNATURE      SIGNATURE DATE						F.I.S.H. NUMBER					
TYPE OF INSPECTION						037-0161-016					
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION											
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re-Inspection Correction Date	Site-Wide Building-Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT		
46	0004	001A	O	Appliances must be plugged in to a dedicated outlet.							
47	0004	001B	O	Appliances must be plugged in to a dedicated outlet.							
48	0004	001B	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1							
49	0004	001D	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)							
50	0004	001D	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1							
51	0004	001E	O	Replace painted ceiling tiles.							
52	0004	001E	O	Remove non-approved furniture that does not have NFPA label or certificate. NFPA 101-10.3.2	1				Electrical Department		
53	0004	001E	O	Door Blocked. Window blocked.	0						
54	0004	001E	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1							
55	0004	001E	O	Light is not operating correctly, please repair light. SREF5 (17)(a)	0						
56	0004	001G	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1	0						
57	0004	001H	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1	1						
58	0004	001H	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)	1				SREF 5(2)(e)(8)j		
59	0004	001I	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1	1				Structural Department		


10/29/2024				 <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303</p> <p><b>COMPREHENSIVE SAFETY INSPECTION</b> FISCAL YEAR: 2024-2025</p>		<b>Amos P. Godby High School</b> <b>SCHOOL/ FACILITY/CAMPUS</b> 1717 West Tharpe Street Tallahassee, Florida 32303				
INSPECTION DATE										
INSPECTOR: Tonnie Rollins										
INSPECTOR SIGNATURE SIGNATURE DATE						F.I.S.H. NUMBER				
TYPE OF INSPECTION						037-0161-016				
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION										
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re-Inspection Correction Date	Site-Wide Building-Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT	
60	0004	001I	O	Replace and sagging ceiling tiles.	1				Structural Department	
61	0004	001J	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1	0					
62	0004	001J	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)	1				Structural Department	
63	0004	002A	O	Replace ceiling tiles missing. Repair wire hanging from ceiling.	0					
64	0004	004	O	Replace and sagging ceiling tiles.	0					
65	0004	004	O	Storage in electrical room is prohibited. SREF 5(17)(b)(2) c and (2)(8)(E)(i)	2				Electrical Department	
66	0004	005	O	Install ADA/FISH sign. SREF 5 (10)(i)(2) and (5)	0					
67	0004	007A	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1	1				Paint Department	
68	0004	400	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j	1					
69	0005	002	O	Exit light is out.	1				Electrical Department	
70	0005	002	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j						
71	0005	002	O	3' Clearance shall be maintained around Fire Standpipe Riser at all times.	2					
72	0005	003	O	Replace missing ceiling tile.	1					
73	0005	004	O	Replace and date water stained and/or broken ceiling tile(s) SREF 5(2)(e)(8)j	1					


10/29/2024				 <p>LEON COUNTY SCHOOLS</p> <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303</p> <p>COMPREHENSIVE SAFETY INSPECTION FISCAL YEAR: 2024-2025</p>		<b>Amos P. Godby High School</b> <b>SCHOOL/ FACILITY/CAMPUS</b> 1717 West Tharpe Street Tallahassee, Florida 32303				
INSPECTION DATE										
INSPECTOR: Tonnie Rollins										
INSPECTOR SIGNATURE      SIGNATURE DATE										
TYPE OF INSPECTION				F.I.S.H. NUMBER						
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION				037-0161-016						
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re-Inspection Correction Date	Site-Wide Building-Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT	
74	0005	004	O	Replace and date water stained and/or broken ceiling tile(s) SREF 5(2)(e)(8)j	1					
75	0005	005	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j	1					
76	0005	006	O	Replace sagging ceiling tile(s). SREF 5 (2) (e) (8) j						
77	0005	008	O	Exit door needs to be marked						
78	0005	010	O	Shut off valves blocked						
79	0005	500	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j						
80	0005	500	O	Water Fountain in hallway needs to be repaired.						
81	0005	015A	O	Light bulb is not operating correctly, please repair light. SREF5 (17)(a)						
82	0006	001A	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)						
83	0006	001A	O	Remove combustible materials from ceiling. NFPA 101-10.3.1						
84	0006	001A	O	Remove non-approved furniture that does not have NFPA label or certificate. NFPA 101-10.3.2						
85	0006	001A	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j						
86	0006	001A	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1						
87	0006	001B	O	Replace damaged ceiling tile(s). SREF 5 (2) (e) (8) j						


10/29/2024				 <p>LEON COUNTY SCHOOLS</p> <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303</p> <p>COMPREHENSIVE SAFETY INSPECTION FISCAL YEAR: 2024-2025</p>		<b>Amos P. Godby High School</b> <b>SCHOOL/ FACILITY/CAMPUS</b> 1717 West Tharpe Street Tallahassee, Florida 32303			
INSPECTION DATE									
INSPECTOR: Tonnie Rollins									
INSPECTOR SIGNATURE      SIGNATURE DATE						F.I.S.H. NUMBER			
TYPE OF INSPECTION						037-0161-016			
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION									
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re-Inspection Correction Date	Site-Wide Building-Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT
88	0006	001B	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1					
89	0006	001C	O	Remove combustible materials from ceiling. NFPA 101-10.3.1					
90	0006	001C	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1					
91	0006	001E	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1					
92	0006	001E	O	Curtains shall have label or certificate verifying flame retardant meeting NFPA 701. NFPA 101-10.3.1.					
93	0006	001E	O	Remove non-approved furniture that does not have NFPA label or certificate. NFPA 101-10.3.2					
94	0006	001E	O	Remove combustible materials from ceiling. NFPA 101-10.3.1					
95	0006	001E	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1					
96	0006	001E	O	Curtains shall have label or certificate verifying flame retardant meeting NFPA 701. NFPA 101-10.3.1.					
97	0006	001E	O	Remove non-approved furniture that does not have NFPA label or certificate. NFPA 101-10.3.2					
98	0006	001E	O	Appliances must be plugged in to a dedicated outlet.					
99	0006	001G	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1					
100	006	001H	O	Remove combustible materials from ceiling. NFPA 101-10.3.1					
101	006	001H	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)					




10/29/2024				 <p>LEON COUNTY SCHOOLS</p> <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303</p> <p>COMPREHENSIVE SAFETY INSPECTION FISCAL YEAR: 2024-2025</p>		Amos P. Godby High School				
INSPECTION DATE						SCHOOL/ FACILITY/CAMPUS				
INSPECTOR: Tonnie Rollins						1717 West Tharpe Street				
						Tallahassee, Florida 32303				
INSPECTOR SIGNATURE      SIGNATURE DATE						F.I.S.H. NUMBER				
TYPE OF INSPECTION				037-0161-016						
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION										
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re-Inspection Correction Date	Site-Wide Building-Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT	
102	006	001H	O	Curtains shall have label or certificate verifying flame retardant meeting NFPA 701. NFPA 101-10.3.1.						
103	006	001H	O	Remove non-approved furniture that does not have NFPA label or certificate. NFPA 101-10.3.2						
104	0006	001K	O	Remove combustible materials from ceiling. NFPA 101-10.3.1						
105	0006	001K	O	Remove combustible materials from ceiling. NFPA 101-10.3.1						
106	0006	001K	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1						
107	0006	001L	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1						
108	0006	001L	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j						
109	0006	001Y	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1						
110	0006	600	O	Exit sign need to be repaired.						
111	0006	600	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j						
112	0007	701	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)						
113	0007	701	O	Curtains shall have label or certificate verifying flame retardant meeting NFPA 701. NFPA 101-10.3.1.						
114	0007	701	O	Remove non-approved furniture that does not have NFPA label or certificate. NFPA 101-10.3.2						
115	0007	702	O	Provide and maintain an unobstructed access to the exit. NFPA 101-4.5.3.2						


10/29/2024				 <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303</p> <p><b>COMPREHENSIVE SAFETY INSPECTION</b> FISCAL YEAR: 2024-2025</p>		<b>Amos P. Godby High School</b>				
INSPECTION DATE						SCHOOL/ FACILITY/CAMPUS				
INSPECTOR: Tonnie Rollins						1717 West Tharpe Street				
						Tallahassee, Florida 32303				
INSPECTOR SIGNATURE      SIGNATURE DATE						F.I.S.H. NUMBER				
TYPE OF INSPECTION				037-0161-016						
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION										
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re- Inspection Correction Date	Site-Wide Building- Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT	
116	0007	702B	O	Replace missing ceiling tile(s). SREF 5 (2) (e) (8) j						
117	0007	703	O	Curtains shall have label or certificate verifying flame retardant meeting NFPA 701. NFPA 101-10.3.1.						
118	0007	703	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)						
119	0007	704	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1						
120	0007	706	O	Gas valve fence gate needs a lock						
121	0007	706	O	Base board needs repair near emergency exit						
122	0007	706A	O	General Housekeeping needed.						
123	0007	707A	O	Replace missing ceiling tile(s). SREF 5 (2) (e) (8) j						
124	0007	708	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)						
125	0007	708	O	Remove combustible materials from ceiling. NFPA 101-10.3.1						
126	0007	708	O	Provide and maintain an unobstructed access to the exit. NFPA 101-4.5.3.2						
127	0007	708	O	General Housekeeping needed.						
128	0008	101C	O	Electrical panels blocked.						
129	0008	101C	O	Light is not operating correctly, please repair light. SREF5 (17)(a)						


10/29/2024				 <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303 COMPREHENSIVE SAFETY INSPECTION FISCAL YEAR: 2024-2025</p>		<b>Amos P. Godby High School</b> <b>SCHOOL/ FACILITY/CAMPUS</b> 1717 West Tharpe Street Tallahassee, Florida 32303					
INSPECTION DATE											
INSPECTOR: Tonnie Rollins											
INSPECTOR SIGNATURE      SIGNATURE DATE						F.I.S.H. NUMBER					
TYPE OF INSPECTION						037-0161-016					
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION											
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re-Inspection Correction Date	Site-Wide Building-Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT		
130	0008	103	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j							
131	0008	104	M	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j							
132	0008	104	O	Replace water stained ceiling tile near exit sign. SREF 5 (2) (e) (8) j							
133	0008	104A	O	Doorway obstructed.							
134	0008	105A	O	Replace damaged ceiling tile(s). SREF 5 (2) (e) (8) j							
135	0008	105C	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j							
136	0008	800	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j							
137	0009	001	O	Light is not operating correctly, please repair light. SREF5 (17)(a)							
138	0009	001	M	Panic lock needs to be replaced on entrance/exit door.							
139	0009	002A	O	Walkway Obstructed.							
140	0009	003	O	Light is not operating correctly, please repair light. SREF5 (17)(a)							
141	0009	003	M	Put sign on door. "Watch your step."							
142	0009	007	O	Replace sagging ceiling tile(s). SREF 5 (2) (e) (8) j							
143	0009	007	O	Receptacle is required by NFPA 70 to be GFCI protected. SREF 5 17 (b)(b)							


10/29/2024				 <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303</p> <p>COMPREHENSIVE SAFETY INSPECTION FISCAL YEAR: 2024-2025</p>	<b>Amos P. Godby High School</b> <b>SCHOOL/ FACILITY/CAMPUS</b> 1717 West Tharpe Street Tallahassee, Florida 32303				
INSPECTION DATE									
INSPECTOR: Tonnie Rollins									
INSPECTOR SIGNATURE      SIGNATURE DATE									
TYPE OF INSPECTION				F.I.S.H. NUMBER					
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION				037-0161-016					
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re- Inspection Correction Date	Site-Wide Building- Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT
144	0009	007	O	Light cover hanging					
145	0009	007	O	Replace Fire Extinguisher					
146	0009	012	O	Replace missing ceiling tile(s). SREF 5 (2) (e) (8) j					
147	0009	012	O	Door hardware is not operating properly. SREF 5 (2)(e)(8)(j)					
148	0009	012	O	Walkway/Doorway blocked.					
149	0010	000	M	Pipe needs to be secure from water fountain removable					
150	0010	000	M	Door hardware is not operating properly. SREF 5 (2)(e)(8)(j)					
151	0010	001	O	Light is not operating correctly, please repair light. SREF5 (17)(a)					
152	0010	007	M	Door hardware is not operating properly. SREF 5 (2)(e)(8)(j)					
153	0010	008	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j					
154	0010	013	O	Repair Fire Extinguisher's mount.					
155	0010	013A	O	Light is not operating correctly, please repair light. SREF5 (17)(a)					
156	0011	000	O	Light is not operating correctly, please repair light. SREF5 (17)(a)					
157	0011	103F	O	Festive lights on walls.					




10/29/2024				 <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303</p> <p><b>COMPREHENSIVE SAFETY INSPECTION</b> FISCAL YEAR: 2024-2025</p>		<b>Amos P. Godby High School</b> <b>SCHOOL/ FACILITY/CAMPUS</b> 1717 West Tharpe Street Tallahassee, Florida 32303				
INSPECTION DATE										
INSPECTOR: Tonnie Rollins										
INSPECTOR SIGNATURE      SIGNATURE DATE						F.I.S.H. NUMBER				
TYPE OF INSPECTION						037-0161-016				
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION										
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re-Inspection Correction Date	Site-Wide Building-Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT	
158	0011	108	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j						
159	0011	108	O	Door hardware is not operating properly. SREF 5 (2)(e)(8)(j)						
160	0012	001	O	Replace water stained and missing ceiling tile(s). SREF 5 (2) (e) (8) j						
161	0012	008	O	Replace water stained and missing ceiling tile(s). SREF 5 (2) (e) (8) j						
162	0012	012	O	Storage in mechanical room is prohibited. SREF 5 (16)(6)a						
163	0012	013	O	Storage in mechanical room is prohibited. SREF 5 (16)(6)a						
164	0013	001	O	Fire extinguisher needs to be replaced X2						
165	0013	001	O	Item needs to be removed on the outside of the exit door.						
166	0013	001	O	Tables need to be removed from the outside of exit door.						
167	0013	002A	M	Wires exposed above door. Need plate cover.						
168	0013	003	M	Light is not operating correctly, please repair light. SREF5 (17)(a)						
169	0013	011	M	Tiles on floor broken.						
170	0013	011	O	Exit/Entrance door needs a sign (watch your step) on door.						
171	0013	012	M	Exit door needs a sign (watch your step) on door.						


10/29/2024				 <p>LEON COUNTY SCHOOLS</p> <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303</p> <p>COMPREHENSIVE SAFETY INSPECTION FISCAL YEAR: 2024-2025</p>		<b>Amos P. Godby High School</b> <b>SCHOOL/ FACILITY/CAMPUS</b> 1717 West Tharpe Street Tallahassee, Florida 32303					
INSPECTION DATE											
INSPECTOR: Tonnie Rollins											
INSPECTOR SIGNATURE				SIGNATURE DATE		F.I.S.H. NUMBER					
TYPE OF INSPECTION						037-0161-016					
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION											
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required		# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re- Inspection Correction Date	Site-Wide Building- Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT	
172	0013	012	M	Door hardware is not operating properly. SREF 5 (2)(e)(8)(j)							
173	0013	012	O	Door on rear of beachers needs a LCS Lock.							
174	0014	001	O	Replace damaged ceiling tile(s). SREF 5 (2) (e) (8) j							
175	0014	001B	O	Replace damaged ceiling tile(s). SREF 5 (2) (e) (8) j							
176	0015	025	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j							
177	0015	025	O	Remove non-approved furniture that does not have NFPA label or certificate. NFPA 101-10.3.2							
178	0017	002	O	Storage in mechanical room is prohibited. SREF 5 (16)(6)a							
179	0018	001	O	General Housekeeping needed.							
180	0018	001	O	Electrical panal and fire extinguisher obstructed							
181	0018	004	O	Wires exposed cover hanging from door							
182	0019	004	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j							
183	0019	005	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j							
184	0019	005B	O	Door blocked leading to next room.							
185	0019	005C	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j							


10/29/2024				 <p>LEON COUNTY SCHOOLS</p> <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303</p> <p><b>COMPREHENSIVE SAFETY INSPECTION</b> FISCAL YEAR: 2024-2025</p>		<b>Amos P. Godby High School</b> <b>SCHOOL/ FACILITY/CAMPUS</b> 1717 West Tharpe Street Tallahassee, Florida 32303					
INSPECTION DATE											
INSPECTOR: Tonnie Rollins											
INSPECTOR SIGNATURE				SIGNATURE DATE		F.I.S.H. NUMBER					
TYPE OF INSPECTION						037-0161-016					
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION											
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required		# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re-Inspection Correction Date	Site-Wide Building-Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT	
186	0019	007	O	Doorway obstructed.							
187	0019	007	O	Replace missed ceiling tile(s). SREF 5 (2) (e) (8) j							
188	0019	007A	O	Door Blocked on other side							
189	0019	007B	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j							
190	0019	007C	O	Remove festive lights off walls.							
191	0019	007C	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)							
192	0019	010	O	Storage in mechanical room is prohibited. SREF 5 (16)(6)a							
193	0020	002	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)							
194	0020	003	O	Replace ceiling tiles painted							
195	0020	003	O	Remove festive lights off walls.							
196	0020	003	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)							
197	0020	003	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1							
198	0020	004	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)							
199	0020	004	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1							


10/29/2024				 <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303</p> <p><b>COMPREHENSIVE SAFETY INSPECTION</b> FISCAL YEAR: 2024-2025</p>		<b>Amos P. Godby High School</b> <b>SCHOOL/ FACILITY/CAMPUS</b> 1717 West Tharpe Street Tallahassee, Florida 32303			
INSPECTION DATE									
INSPECTOR: Tonnie Rollins									
INSPECTOR SIGNATURE      SIGNATURE DATE						F.I.S.H. NUMBER			
TYPE OF INSPECTION						037-0161-016			
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION									
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re-Inspection Correction Date	Site-Wide Building-Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT
200	0020	004	O	Curtains shall have label or certificate verifying flame retardant meeting NFPA 701. NFPA 101-10.3.1.					
201	0020	005	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1					
202	0020	005	O	Remove festive lights off walls.					
203	0020	005	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)					
204	0020	800	M	ADA/FBC door hardware shall be installed FBC-A-309.4 and SREF (5) 8(b)4					
205	0020	800	O	Tiles broken on floor under water fountain.					
206	0021	001	M	Replace ceiling tile(s) missing.. SREF 5 (2) (e) (8) j Lights					
207	0021	003	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j					
208	0021	004	O	Storage in mezzanine is prohibited.					
209	0021	006	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j					
210	0021	012	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1					
211	0021	012	O	Appliances must be plugged in to a dedicated outlet.					
212	0021	012	O	Curtains shall have label or certificate verifying flame retardant meeting NFPA 701. NFPA 101-10.3.1.					
213	0021	020	O	Remove combustible materials from ceiling. NFPA 101-10.3.1					



10/29/2024				 <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303</p> <p><b>COMPREHENSIVE SAFETY INSPECTION</b> FISCAL YEAR: 2024-2025</p>		<b>Amos P. Godby High School</b> <b>SCHOOL/ FACILITY/CAMPUS</b> 1717 West Tharpe Street Tallahassee, Florida 32303				
INSPECTION DATE										
INSPECTOR: Tonnie Rollins										
INSPECTOR SIGNATURE      SIGNATURE DATE						F.I.S.H. NUMBER				
TYPE OF INSPECTION						037-0161-016				
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION										
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re-Inspection Correction Date	Site-Wide Building-Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT	
214	0021	020	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1						
215	0021	021	O	Replace ceiling tile(s) missing. SREF 5 (2) (e) (8) j						
216	0021	021	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j						
217	0021	021	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j						
218	0021	022	M	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j x3 (light/Outlet)						
219	0021	023	O	Provide and maintain an unobstructed access to the emergency escape window. NFPA 101-15.2.11.1.1						
220	0021	023	M	Replace water stained ceiling tiles. SREF 5 (2) (e) (8) j (speaker) x 2						
221	0021	023	O	Replace sagging ceiling tiles. SREF 5 (2) (e) (8) j						
222	0021	024	O	Provide and maintain an unobstructed access to the exit. NFPA 101-4.5.3.2						
223	0021	024	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)						
224	0021	024	M	Replace missing ceiling tile. Outlet						
225	0021	800	O	Exit lights hanging broken.						
226	0022	001	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)						
227	0022	001A	O	Doorway obstructed.						

10/29/2024				 <p><b>LEON COUNTY SCHOOLS</b></p> <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303</p> <p><b>COMPREHENSIVE SAFETY INSPECTION</b> FISCAL YEAR: 2024-2025</p>		<b>Amos P. Godby High School</b>				
<b>INSPECTION DATE</b>						<b>SCHOOL/ FACILITY/CAMPUS</b>				
<b>INSPECTOR: Tonnie Rollins</b>						1717 West Tharpe Street				
						Tallahassee, Florida 32303				
<b>INSPECTOR SIGNATURE      SIGNATURE DATE</b>						<b>F.I.S.H. NUMBER</b>				
<b>TYPE OF INSPECTION</b>				<b>037-0161-016</b>						
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION										
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re-Inspection Correction Date	Site-Wide Building-Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT	
228	0022	002B	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j						
229	0022	002C	M	Inspect fire extinguisher annually.						
230	0022	002E	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j						
231	0022	002F	O	Replace missing ceiling tile(s). SREF 5 (2) (e) (8) j						
232	0022	004	O	Fire Extinguisher Blocked						
233	0022	004F	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j						
234	0022	005	O	Combustible materials on wall shall not exceed 20% in a nonsprinklered building. NFPA 101-15.7.4.3 (1)						
235	0022	005B	O	General Housekeeping needed.						
236	0022	007	O	Replace damaged ceiling tile(s). SREF 5 (2) (e) (8) j						
237	0022	007A	O	Replace water stained ceiling tile(s). SREF 5 (2) (e) (8) j						
238	0027	001	O	A/C duct vent cover missing x 2						
239	0027	001A	O	Unable to access.						
240	0027	002A	O	A/C duct vent cover hanging.						
241	0028	001	O	Unable to access.						
242	0030	301	O	Unable to access.						

10/29/2024				 <p><b>LEON COUNTY SCHOOLS</b></p> <p>FACILITIES &amp; CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303</p> <p>COMPREHENSIVE SAFETY INSPECTION FISCAL YEAR: 2024-2025</p>				<b>Amos P. Godby High School</b>			
INSPECTION DATE								SCHOOL/ FACILITY/CAMPUS			
INSPECTOR: <b>Tonnie Rollins</b>								1717 West Tharpe Street			
								Tallahassee, Florida 32303			
INSPECTOR SIGNATURE      SIGNATURE DATE								F.I.S.H. NUMBER			
TYPE OF INSPECTION								037-0161-016			
<input checked="" type="checkbox"/> FIRE <input checked="" type="checkbox"/> CASUALTY <input checked="" type="checkbox"/> SANITATION											
Item #	Building Number	Room Number	M O C	Deficiency Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re-Inspection Correction Date	Site-Wide Building-Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT		
243	0035	000	O	Unable to access.	1						
244	0099	407	O	Unable to access.	1				Building Automation		
<b>END OF SREF INSPECTION REPORT</b>											
A re-inspection of the identified deficiencies will be preformed approximately _____ days subsequent of inspection date. <b>Re-Inspection Date:</b> _____											
The principal shall hold at least one (1) fire drill during each month, with an additional drill being held within the first 30 days of school.              YES <input type="checkbox"/> NO <input type="checkbox"/>											
Reviewed Emergency Generator Report.              YES <input type="checkbox"/> NO <input type="checkbox"/> Emergency Generator Report up-to-date as of SREF inspection.              YES <input type="checkbox"/> NO <input type="checkbox"/>											
Signature of facility administrator attesting to Fire Evacuation Drills and review of inspection report acknowledging awareness of discovered deficiencies:											

**X** 

Leon County  
School/Site Administrator