

10/23/12

INSPECTION DATE

Inspector Signature

SIGNATURE DATE



LEON COUNTY SCHOOLS
MAINTENANCE DEPARTMENT
 "Our hands keep their minds working"

Adult and Community Ed.
 SCHOOL/FACILITY/CAMPUS

037-9262-926

F.I.S.H./F.I.C.E. NUMBER

283 Trojan Trail, Tallahassee

ADDRESS

TYPE INSPECTION

☒ FIRE SAFETY
 ☒ CASUALTY
 ☒ SANITATION

COMPREHENSIVE SAFETY INSPECTION

FISCAL YEAR 2012-13

Dept	Work Order	Building Number	Room Number	M O C	Estimated Cost	Deficiency Description and Corrective Action Required	Number of Times Def. Cited Before	Sched for Correction NLT	Completion Date	Line Item #
	0	0003	313	O	0	Extension cords cannot be used as permanent power.	1	Immed		1
	0	0011	001	O	0	Remove shade obscuring exit door.	0	Immed.		2
ELE	241991	0001	101	M	0	Emergency light is inoperable.	0	11/23/12		3
ELE	241991	0007	000	M	0	Near building 7 utility pole needs to be resecured and grounded properly and wires installed feeding lights on pole.	0	11/23/12		4
STR	241993	0001	116	M	0	Secondary exit door does not close properly.	1	11/23/12		5
STR	241993	0099	177	M	0	Ramp leading up to portable is missing wheel chair bollards and has rotted wood needs to be repaired or replaced.	0	11/23/12		6
STR	241993	0099	402	M	0	Add wheelchair bollards or railing to access ramp leading up to portable.	0	11/23/12		7

Printed: 10/30/2012 9:17:01 AM

The principal shall hold at least one (1) emergency drill during each month, with an additional drill being held within the first 30 days of school.

☒ Yes
 ☐ No

Signature of facility administrator attesting to Emergency Evacuation Drills and review of inspection report acknowledging awareness of discovered deficiencies

Signature Date